



# IECEX Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

Certificate No.: **IECEX PTB 22.0001X** Page 1 of 3 [Certificate history:](#)  
Status: **Current** Issue No: 0  
Date of Issue: 2022-01-28  
Applicant: **R. STAHL Schaltgeräte GmbH**  
Am Bahnhof 30  
74638 Waldenburg  
Germany  
Equipment: **CPU Module, type 9442/32-10-00**  
Optional accessory:  
Type of Protection: **Intrinsic Safety**  
Marking: Ex ib [Ia Ga] [Ib Gb] IIC T4 Gb and  
[Ex Ia Da][Ex Ib Db] IIIC


Approved for issue on behalf of the IECEx  
Certification Body:

**Dr.-Ing. Martin Thedens**

Position:

**Head of Department "Explosion Protection in Sensor Technology  
and Instrumentation"**

Signature:  
(for printed version)

  
2.2.22

Date:

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting [www.iecex.com](http://www.iecex.com) or use of this QR Code.



Certificate issued by:

**Physikalisch-Technische Bundesanstalt (PTB)**  
Bundesallee 100  
38116 Braunschweig  
Germany





# IECEX Certificate of Conformity

Certificate No.: **IECEX PTB 22.0001X**

Page 2 of 3

Date of issue: 2022-01-28

Issue No: 0

Manufacturer: **R. STAHL Schaltgeräte GmbH**  
Am Bahnhof 30  
74638 Waldenburg  
Germany

Additional  
manufacturing  
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEX Quality system requirements. This certificate is granted subject to the conditions as set out in IECEX Scheme Rules, IECEX 02 and Operational Documents as amended

#### STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

**IEC 60079-0:2017** Explosive atmospheres - Part 0: Equipment - General requirements  
Edition:7.0

**IEC 60079-11:2011** Explosive atmospheres - Part 11: Equipment protection by intrinsic safety "I"  
Edition:6.0

This Certificate **does not** indicate compliance with safety and performance requirements other than those expressly included in the Standards listed above.

#### TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

[DE/PTB/ExTR22.0001/00](#)

Quality Assessment Report:

[DE/BVS/QAR10.0002/17](#)



# IECEX Certificate of Conformity

Certificate No.: **IECEX PTB 22.0001X**

Page 3 of 3

Date of issue: 2022-01-28

Issue No: 0

## EQUIPMENT:

Equipment and systems covered by this Certificate are as follows:

The CPU Module, type 9442/32-10-00 is one of the basic modules of the Remote I/O-System, type IS1 / IS1+ and serves as the communication unit. It receives signals from the I/O-Modules (on the BusRail) and transmits them to the Process Logic Controller (PLC) or other communication partners using associated interfaces. The equipment is supplied from an intrinsically safe circuit provided by the Power Module. Two intrinsically safe circuits are used for communication with system-modules plugged onto the Socket or the BusRail. Signal transmission to the PLC or other communication partners is carried out via Ethernet, RS485 or USB interfaces which are designed to types of protection Intrinsic Safety "Ex ia" or "Ex ib".

For further information reference is made to the annex.

## SPECIFIC CONDITIONS OF USE: YES as shown below:

1. Inside the hazardous area the CPU Module, type 9442/32-10-00 shall be installed into an enclosure that corresponds to an acknowledged type of protection according to EN 60079-0 and that provides a minimum degree of protection of IP 54 according to EN 60529.
2. Outside the hazardous area the CPU Module, type 9442/32-10-00 shall be installed into an enclosure that provides a minimum degree of protection of IP 54 according to EN 60529 or inside an area having a maximum pollution degree 2 / overvoltage category III.
3. The CPU Module, type 9442/32-10-00 shall only be operated with the Socket of type 9496/3\*-0\*-00. Two CPU-Modules are permitted as a maximum in one Remote I/O-system, type IS1 / IS1+.

## Annex:

[COCA22.0001X-issue0\\_1.pdf](#)



Applicant: R.STAHL Schaltgeräte GmbH  
Electrical Apparatus: CPU Module, type 9442/32-10-00

#### Description of equipment

In addition to the Power Module, type 9445/3\*-12 and the Socket of type 9496/3\*-0\*-00 and 9496/3\*-0\*-00 which are separately certified, the CPU Module, type 9442/32-10-00 is one of the basic modules of the Remote I/O-System, type IS1 / IS1+. The CPU Module is plugged into one of the 3 resp. 4 slots on the socket and bolted by a screw and it is hence electrically connected to the Power Module and other system modules which are connected to the sockets or to the BusRail, type 9494/\*\*-\*\* that is also separately certified. The CPU Module serves as a communication unit. It receives signals from the I/O-Modules (on the BusRail) and transmits them to the Process Logic Controller (PLC) or other communication partners using associated interfaces. The equipment is supplied from an intrinsically safe circuit provided by the Power Module. Two intrinsically safe circuits are used for communication with system-modules plugged onto the Socket or the BusRail. Signal transmission to the PLC or other communication partners is carried out via Ethernet, RS485 or USB interfaces which are designed to types of protection Intrinsic Safety "Ex ia" or "Ex ib".

The electronic circuitry is arranged on two PCB's which are mounted onto a metal carrier. This assembly is installed in a plastic enclosure.

The CPU Module, type 9442/32-10-00 is intended for the installation in areas requiring equipment of category 3, 2 or in the safe area.

The permissible range of the ambient temperature depends on the installation as follows:

$T_a = -40\text{ °C} \dots +75\text{ °C}$  when socket is mounted on a DIN-mounting rail (BusRail)  
and bolted onto a carrier plate  
 $T_a = -40\text{ °C} \dots +65\text{ °C}$  when socket is mounted on a DIN-mounting rail (BusRail)  
without carrier plate

#### Electrical data

##### Intrinsically safe circuits:

The intrinsically safe circuits are considered system-internal circuits if the CPU-Module is plugged into the associated socket and bolted as intended.

Supply circuit  
Slot connector V100, pins A ... D

type of protection Intrinsic Safety Ex ia IIC  
Maximum values:  
 $U_i = 26.2\text{ V}$   
 $I_i = 0.446\text{ A}$   
 $P_i = 11.7\text{ W}$

Sense-line  
Slot connector V100, pins E, F

type of protection Intrinsic Safety Ex ia IIC  
Maximum values:  
 $U_i = U_o = 26.2\text{ V}$   
 $I_o = 2.7\text{ mA}$



BusRail signal  
Slot connector V100, pins K, L

type of protection Intrinsic Safety Ex ia IIC  
Maximum values:  
 $U_i = U_o = 6.6 \text{ V}$   
 $I_o = 98 \text{ mA}$  (linear characteristic)  
 $L_i$  negligibly low  
 $C_i$  negligibly low

Backplane signal  
Slot connector V100, pins S ... AJ

type of protection Intrinsic Safety Ex ia IIC  
Maximum values:  
 $U_i = U_o = 5 \text{ V}$   
 $I_i = 2 \text{ A}$   
 $I_o = 84 \text{ mA}$  (linear characteristic)  
 $L_i$  negligibly low  
 $C_i = 2.5 \mu\text{F}$

The intrinsically safe circuits are safely electrically isolated from each other and from the intrinsically safe data circuits up to a peak value of the nominal voltage of 60 V. The intrinsically safe supply circuit and the intrinsically safe Sense-line are electrically interconnected.

Intrinsically safe data circuits:

RS485-interface X001  
D-Sub 9-pin connector

type of protection Intrinsic Safety [Ex ia Ga] IIC  
and [Ex ia Da] IIIC

$U_o = 4.2 \text{ V DC}$   
 $I_o = 149 \text{ mA}$   
 $U_i = \pm 4.2 \text{ V}$   
 $L_i$  negligibly low  
 $C_i$  negligibly low

galvanically separated installation of the communication lines, the Screen may be earthed according to EN 60079-14

Ethernet-interfaces X002.A and X002.B  
RJ 45 connector

type of protection Intrinsic Safety [Ex ia Ga] IIC  
and [Ex ia Da] IIIC

$U_o = 5 \text{ V}$   
 $I_o = 425 \text{ mA}$   
 $U_i = 5 \text{ V}$   
 $L_i = 200 \text{ nH}$   
 $C_i$  negligibly low

galvanically separated installation of the communication lines, the Screen may be earthed according to EN 60079-14

Standard: 100Base TX IS  
Transfer rate: 10/100 Mbit/s, auto negotiation

USB-interface X003  
USB 2.0 Typ A connector

type of protection Intrinsic Safety [Ex ib Gb] IIC  
and [Ex ib Db] IIIC

$U_o = 5.55 \text{ V DC}$   
 $I_o = 687 \text{ mA DC}$  (rectangular characteristic)  
 $P_o = 2 \text{ W}$   
 $L_i$  negligibly low  
 $C_i = 1,6 \mu\text{F}$

galvanically separated installation of the communication lines and the screen

only for connection of passive components without supply into the intrinsically safe circuit

The following tables show the combinations of  $L_o$  and  $C_o$  including occurring line reactances for the connection to the USB interface in the respective gas group. The internal capacitance  $C_i = 1.6 \mu\text{F}$  is already taken into account. The maximum values for  $L_o$  and  $C_o$  are highlighted in grey.

For IIC (according to ISPARK 6.2):

|  |     |     |     |     |      |      |      |      |
|--|-----|-----|-----|-----|------|------|------|------|
| <b><math>L_o</math> [<math>\mu\text{H}</math>]</b> | 150 | 100 | 50  | 20  | 10   | 5    | 2    | 1    |
| <b><math>C_o</math> [<math>\mu\text{F}</math>]</b> | 0.5 | 1.5 | 3.4 | 6.6 | 10.4 | 16.4 | 38.4 | 52.4 |

For IIB / IIIC (according to ISPARK 6.2):

|  |     |     |      |      |      |      |       |       |       |
|--|-----|-----|------|------|------|------|-------|-------|-------|
| <b><math>L_o</math> [<math>\mu\text{H}</math>]</b> | 610 | 500 | 200  | 100  | 50   | 20   | 10    | 5     | 2     |
| <b><math>C_o</math> [<math>\mu\text{F}</math>]</b> | 6.3 | 8.3 | 17.4 | 26.4 | 38.4 | 66.4 | 118.4 | 288.4 | 998.4 |

#### Special conditions for safe use

1. Inside the hazardous area the CPU Module, type 9442/32-10-00 shall be installed into an enclosure that corresponds to an acknowledged type of protection according to EN 60079-0 and that provides a minimum degree of protection of IP 54 according to EN 60529.
2. Outside the hazardous area the CPU Module, type 9442/32-10-00 shall be installed into an enclosure that provides a minimum degree of protection of IP 54 according to EN 60529 or inside an area having a maximum pollution degree 2 / overvoltage category III.
3. The CPU Module, type 9442/32-10-00 shall only be operated with the Socket of type 9496/3\*-0\*-00. Two CPU-Modules are permitted as a maximum in one Remote I/O-system, type IS1 / IS1+.